

## **SRF Public Notice**

### **PUBLIC HEARING NOTICE**

The City of State Center will be holding a Public Hearing to review an application for a State Revolving Fund (SRF) loan and to make available to the public the contents of an environmental information document and the City's project plan. These documents include design and environmental information related to the proposed improvements to the City's wastewater treatment infrastructure.

The proposed project includes improvements to the existing wastewater treatment plant and consists of abandoning the existing wet well in-place and the construction of a prefabricated HDPE wet well (same depth) with (3) – 20 HP submersible chopper pumps and all necessary appurtenances. A 15'L x 10' pre-engineered structural steel building would be constructed adjacent to the wet well to house valves, control panels, and all necessary appurtenances and electrical connections. Additionally, a new 10" DIP forcemain will be installed from the new dry well to the existing forcemain. The new 10" forcemain will have a depth in the range of 11-5 ft below grade, and width of 6 ft.

Below is the method of construction for the design.

- General Contractor (GC) will perform dewatering, shoring and backfill around the HDPE wet well.
- GC will pour concrete for flattop / building pad
- Once concrete is cured, the GC will set the building and anchor to the slab and land the incoming power feed from the main PM disconnect switch.
- GC will make influent / Effluent pipe connections

The purpose of this Public Hearing is to inform area residents of the community of State Center of this proposed action, discuss the actual cost and user fees associated with this project, and to address citizen's concerns, if any, with the plan.

The Public Hearing location and time are as follows:

July 16, 2024, at 6:30 p.m.  
State Center City Hall  
118 E Main Street  
State Center, Iowa 50247

All interested persons are encouraged to attend this hearing. Written comments on this proposal may also be submitted prior to the hearing. Questions regarding this hearing or the availability of documentation may be directed to Project Contact, Lori Bearden, City Clerk at 641-483-2559. Additionally, public comments can be sent to [SRF-PC@dnr.iowa.gov](mailto:SRF-PC@dnr.iowa.gov).